

GOA STATE INFRASTRUCTURE DEVELOPMENT CORPORATION LIMITED
“Construction of 50 Bedded Integrated AYUSH Hospital at Velguem, Bicholim, Goa”

Tender Notice No. : **GSIDC/ENGG./NIT-118/2021-22** dated 17th December 2021.


REPLY TO PRE-BID QUERIES: Last date of submission was on 27th December 2021.

COMMON SET OF DEVIATION (I)

SR. NO.	VOLUME/ CHAPTER/ CLAUSE NO. / ITEM NO./PAGE NO.	CLARIFICATION SOUGHT BY PROSPECTIVE BIDDERS	DECISION OF GSIDC
1	Volume III - Item no. E-10	Item no. E-10 - S.S. 304 grade hand rail in main stair case - Drawings Required.	Refer Dwg. No. H-A-501(Revised) enclosed herewith instead of H-A-501 of Volume-IV. Item no. E-10, consists of only handrail, as shown in Detail 1, of Dwg. No. H-A-501(Revised).
2	Volume-III - Item no. F-21	Item no. F-21 – Antistatic Conductive flooring - Make Required.	Tarkett (UK), Gerflor (France), Forbo and Armstrong
3	Volume-III - Item no. F-22	Item no. F-22 – Corner Guard - Make Required.	Fasttrack, RDPlast and Windowtech
4	Volume-III - Item no. F-23	Item no. F-23– Hand Rail cum Crash Guard - Make Required.	Fasttrack, RDPlast and Windowtech
5	Volume-III - Item no. H-19	Item no, H-19 – Anti microbial Paint on wall - Make Required.	Liquid Plastic -(UK), Green Strek (US), Sika AG (EU) and SKK Japan
6	Volume-III - Item no. I-6	Item no. I-6– Rubberized Speed Breaker - Make Required.	There is no standard approved makes for rubberized speed breaker. Speed breakers need to adhere to IRC specifications.
7	Volume-III – Item no. M-1, 2, 3, 4, 5, 6, 7, 10, 11, 12, 13, 14, 15, 16, 17, 22, 54, 61, 62	Item no. M-1, 2, 3, 4, 5, 6, 7, 10, 11, 12, 13, 14, 15, 16, 17, 22, 54, 61, 62 - Internal Plumbing System - Item/Product Code Required.	Approved makes of Plumbing items mentioned have been specified in the Chapter 3: Approved Brands/Makes and Manufacturers of Volume - II and the product code cannot be specified at this stage.

GOA STATE INFRASTRUCTURE DEVELOPMENT CORPORATION LIMITED
“Construction of 50 Bedded Integrated AYUSH Hospital at Velguem, Bicholim, Goa”

8	Volume- III – Item No. M-57	Item No. M-57 – STP Plant – Make Required.	The makes of different components of STP Plant are specified on Page no. 115 of Volume - II.
9	Volume- III – Item No. O.7, 8	Volume- III – Item No. O.7, 8 - RCC Hume pipe - Class Required.	NP2 class.



2 DETAIL
1:5



LIFT
C O O C F O

REVISION NO :
R0